



Government Of West Bengal
Office Of The Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services
6, Diamond Harbour Road, Silpara, Kol-700008

Memo no.: IND/WB/FES/20192020/78540

Date: 18-01-2023

From:

Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services

To: BBIT Public School

Nischintapur, Budge Budge, South 24 Parganas, Pin-700137

Sub: Renewal of Fire Safety Certificate for the occupancy of an existing G+III storied under group Institutional building in the name and style 'BBIT Public School' at the premises no. Nischintapur, Budge Budge, under Nischintapur Gram Panchayet, Dist.- 24 Pgs. (South), Kolkata- 700137.

This is in reference to your application no. 0125191221200391 dated 22-12-2022 regarding the Renewal of Fire Safety Certificate for the occupancy of an existing G+III storied under group Institutional building in the name and style 'BBIT Public School' at the premises no. Nischintapur, Budge Budge, under Nischintapur Gram Panchayet, Dist.- 24 Pgs. (South), Kolkata- 700137.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

To up-keep the Fire Safety Measures of the aforesaid building the following safety measures are to be incorporated:-

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear, particularly lines

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191221200391.

above false ceiling and ducts.

5. Fire Control Room with CCTV system will have to be maintained.

6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.

7. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and capable to operate in the event of Fire and Testing.

8. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.

9. Transformer and switch gear room shall be protected with automatic CO2 or D.C.P. Fire Extinguishers conforming I.S. specification.

10. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.

11. Unauthorized cooking arrangement in any floor of the building using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.

12. Arrangement shall have to be made for regular checking, testing and maintenance of all the firefighting installation in the building to keep them in perfectly good working condition at all the times.

13. If required the old lines shall have to be replaced with new lines and the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.

14. Periodical flashing of water from the Hydrant and Sprinkler pipe lines shall be made to maintain the efficient working performance of above mentioned system.

15. The Fire Safety Audit to be conducted in a regular interval and to be recorded in the fire prevention maintenance register.

16. Covering above courtyard at roof level shall be removed as early as possible. Otherwise, revised Fire Safety Recommendation shall be obtained from this directorate followed by Fire Safety Certificate in order to mitigate smoke locking during emergency.

17. This Fire Safety Certificate is valid for 3 (Three) year from the date of issue of this letter and have to be renewed within validity limit.

18. A certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all the life and fire safety arrangements and installation of the building.

Signature valid

Digitally signed by TARUN
KUMAR DUTTA
Date: 2023.07.18 17:23:07 IST

Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services